

Vill: West Dhantala  
P.O.: Satellite Township  
Dist.: Jalpaiguri  
West Bengal, 734015



Ref No- SN/SCP/03

Date- 18.03.2026

### CERTIFICATE OF STRUCTURAL STABILITY

I hereby certify that I have personally inspected the existing G+2 storied school building of Central School for Tibetans / Sambhota Tibetan School, located at Mouza kalimpong, J.L. No. 056, Khatian No. 7548 (L.R.), Plot No. 9 (R.S.), 1412 (L.R.), Ward No. VII, 11th Mile, P.O/ P.S. Kalimpong – 734301, under the jurisdiction of Kalimpong Municipality. The building is currently being used for educational purposes. A detailed structural inspection has been carried out, including visual examination and Non-Destructive Testing (NDT) such as Rebound Hammer Test and Ultrasonic Pulse Velocity (UPV) Test on key structural members like columns, beams and slabs. Based on the inspection and test results, it is observed that the concrete quality is generally moderate to good with some variation across different members, and no major structural distress such as significant cracking, settlement, tilting, or deformation has been noticed. In my opinion, the building is structurally stable and safe for use under normal loading conditions, including occupancy by students and staff, subject to proper maintenance and periodic monitoring. This certificate is issued based on the current condition of the structure and NDT results, provided no structural alterations are carried out without proper engineering approval.

*Simul Chandra Pal*  
Er. Simul Chandra Pal  
Structural Engineer, Class-II  
SMC Empanelment No-II/10  
Vill-West Dhantala, P.O.Satellite Township  
Dist-Jalpaiguri, West Bengal (734015)  
Ph No.- 9614151953  
Email ID-structanirman@gmail.com



(SIMUL CHANDRA PAL)

SIGNATURE OF STRUCTURAL ENGINEER

Contact Details: 9614151953 | structanirman@gmail.com

*Attested*

PRINCIPAL  
केन्द्रीय तिब्बती विद्यालय  
Central School for Tibetans  
कालिम्पोड (प० बंगाल)  
Kalimpong (W.B.)